

# Industrial Wastewater Pretreatment Monitoring Report

Milbank Mfg. Co.

Year 99 Month OCTOBER

Date	Flow in Gallons	pH	Zinc	Oil and Grease	COD	CBOD	TSS
1	690	9.65					
2							
3							
4	2480	9.75					
5	2270	9.86					
6	2410	9.96					
7	2920	9.93	0.020	5			
8							
9							
10							
11							
12							
13							
14	2410	9.96					
15	970	9.91					
16							
17							
18	3100	9.73					
19							
20							
21	2780	9.90	0.11	8	390	150	16
22	2570	9.85					
23							
24							
25							
26							
27	1800	9.92					
28	4570	9.77					
29							
30							
31							
Daily Limit	N/A	6-10	1.25	100		N/A	N/A
AVERAGE	2409	9.84	.06	6.5	390	150	16
MAXIMUM	4570	9.96	.11	8			
MINIMUM	690	9.65	.020	5			

molybdenum

< 0.020

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief is, true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Richard Tyler  
Authorized Company Representative

DATE 11-19-99